

§ 76.05-25 Hand portable fire extinguishers and semiportable fire extinguishing systems.

(a) Approved hand portable fire extinguishers and semiportable fire extinguishing systems shall be installed on all vessels as set forth in subpart 76.50.

(b) [Reserved]

Subpart 76.10—Fire Main System, Details

§ 76.10-1 Application.

(a) The provisions of this subpart, with the exception of § 76.10-90, shall apply to all fire main installations contracted for on or after May 26, 1965. Installations contracted for prior to May 26, 1965, shall meet the requirements of § 76.10-90.

(b) [Reserved]

§ 76.10-3 Water availability.

(a) On all vessels on an international voyage, regardless of the date of construction, water pressure from the firemain protecting enclosed spaces shall be immediately available by maintenance of water pressure on the firemain at all times when passengers are aboard the vessel, or by remote control of fire pumps which control shall be easily operable and readily accessible.

(b) Where approved remote controls are not installed, an alarm shall be fitted which will sound in the engine room indicating a drop of water pressure on the system.

[CGFR 67-87, 32 FR 19181, Dec. 20, 1967]

§ 76.10-5 Fire pumps.

(a) Vessels shall be equipped with independently driven fire pumps in accordance with table 76.10-5(a).

TABLE 76.10-5(a)

Gross tons		Minimum number of pumps		Hose and hydrant size, inches	Nozzle orifice size, inches	Length of hose, feet
Over	Not over	International voyage	Other			
.....	100	2	1	1½	½	50
100	500	2	1	1½	⅝	50
500	1,500	2	2	1½	⅝	50
1,500	4,000	2	2	1½	⅞	150

TABLE 76.10-5(a)—Continued

Gross tons		Minimum number of pumps		Hose and hydrant size, inches	Nozzle orifice size, inches	Length of hose, feet
Over	Not over	International voyage	Other			
4,000	3	3	1½	⅞	150

¹ 75 feet of 1½-inch hose and ⅝-inch nozzles may be used where specified by § 76.10-10(b).

(b) Vessels on an international voyage shall have a minimum total fire pump capacity at least equal to two-thirds of the required total bilge pump capacity, but in no case less than that required by this section. Each of the required fire pumps shall have a capacity not less than 80 percent of the total required capacity divided by the number of required pumps.

(c) Each pump shall be capable of delivering water simultaneously from the two highest outlets at a Pitot tube pressure of approximately 50 p. s. i. Where one or both of these outlets is a 1½-inch siamese fitting, both branches of the siamese fitting at each such outlet shall be utilized for the purpose of this requirements.

(d) Fire pumps shall be fitted on the discharge side with relief valves set to relieve at 25 p. s. i. in excess of the pressure necessary to maintain the requirements of paragraph (c) of this section or 125 p. s. i., whichever is greater. Relief valves may be omitted if the pumps, operating under shutoff conditions, are not capable of developing a pressure exceeding this amount.

(e) Fire pumps shall be fitted with a pressure gauge on the discharge side of the pumps.

(f) Fire pumps may be used for other purposes provided at least one of the required pumps is kept available for use on the fire system at all times. In no case shall a pump having connection to an oil line be used as a fire pump. Branch lines connected to the fire main for purposes other than fire and deck wash shall be arranged so that the requirements of paragraphs (b) and (c) of this section and any other services installed on the fire main can be met simultaneously.